

**CPWD**



Telephone : 4716437

ASSISTANT ENGINEER (E)  
CENTRAL ELECTRICAL SUB DIVISION 1/IV

GOVERNMENT OF INDIA  
CENTRAL PUBLIC WORKS DEPARTMENT

GPRA Campus,  
K.K. Nagar,  
Chennai - 600 078.

No. 57(1)/CESD-1/IV/2005

**CPWD**

Date. 23.09.05

**TO WHOMSOEVER IT MAY CONCERN**

This is to certify that 2 nos. High Mast Lights commissioned by M/s Spaceage Switchgears Limited, Haryana, at Chennai Convention Centre For Chennai Trade Centre at Chennai are working satisfactorily.

M. & L. Srinivasan  
23/9/05  
Assistant Engineer (E),  
CESD -1/IV, CPWD,  
K.K.Nagar, Chennai.78

**KIRLOSKAR BROTHERS LIMITED**



Enriching Lives

25-09-07

TO WHOM SO EVER IT MAY CONCERN

This is to certify that the M/s. **SPACEAGE** – HYUNDAI make of **ACB's**, **MCCB's** and **Contactors** are used for our Dindigul and Tirunelveli Schemes A/c. **TWAD Board**.

The Equipments are commissioned and as on date no Complaints were received.

We are satisfied with the components and after sales they are giving good service and commissioning co – ordination.

Thanking You,

Yours Faithfully,  
For Kirloskar Brothers Ltd

A handwritten signature in black ink, appearing to read "L. Jothi", written over a horizontal line.

L. Jothi  
Asst. Manager – (Projects)



# Sudhir Gensets Limited

507, International Trade Tower, Nehru Place, New Delhi-110019  
Ph. : 6466293, 6444111, 6484376 Fax : 91-11-6467950  
• E-mail : sgidel@vsnl.com • website : www.sudhirgensets.com



Ref. No.: SGL/pa/01-02/jul

Date: 02-07-2001

Sudhir Gensets

To Whom It May Concern

This is to certify that we have been using **Spaceage MCCB** of ratings upto 400 Amp for our DG set panels for last eight months. **The performance & service has been very satisfactorily.**

for Sudhir Gensets Limited

Say  
Authorised Signatory

# BHARAT SANCHAR NIGAM LIMITED

उत्तर में उद्दान करें  
In reply please quote

प्रेषक  
From

Sub Divisional Engineer (E)  
BSNL Electrical Sub-Division Stores  
No.18, V.V. Koil Street,  
Saidapet, Chennai - 600 015.

BSNL

सेवा में  
To

Spaceage Switchgears Ltd  
Chennai - 41.

सं.  
No. W(114)/ESD/S/CH/ 708 Dated at Ch

दि  
the 5th Dec. 2005


विषय :  
SUBJECT : Usage of Spaceage Switchgears  
under Electrical Sub-Divn (Stores)  
reg.

This is to certify that MCCB of 400A, 4 pole  
supplied by M/s Spaceage Switchgear Ltd being used in our  
125 KVA E/A set at TE Bldg Raj Bhawan and is working  
satisfactorily till date.

F. Verhast  
Sub Divisional Engineer (E)  
BSNL Electrical Sub-Division Stores  
No.18, V.V. Koil Street,  
Saidapet, Chennai - 600 015.



TIN : CBER160061  
ECC No. : AAA.CJ.4276 (X) M001  
CER No. : 16/JOHNS/MIA/92 dt. 23.6.92  
Bankers : State Bank of India  
Malviya Nagar Jaipur - 302017  
RBI Code No. : JJ-000230  
IEC No. : 1390003108  
EEPC RCMC No. : EPC/D/R 2885/E 199 (SSI)  
SSI Regn. No. : 17/13/01598/PMT/SSI  
NSIC Regn. No. : NSIC/GP/RAJ/1(724)90



**JOHNS ELECTRIC CO. PVT. LTD.**  
C-25 (B), MALVIYA INDUSTRIAL AREA, JAIPUR-302 017, RAJ., INDIA


Office Telephone : +91 141-2751694  
+91 141-2751357  
+91-9829051694  
+91-9314504829  
Fax : +91 141-2751890  
E-mail : johnpanl\_jp1@sancharnet.in  
johnpanl@datainfosys.net  
Website : www.johnselectric.net

● Control Panel      ● Automation      ● Consultancy      ● Training      ● Total Electrical in Project

**To whom so it may concern**

This is to certify that **Spaceage** "Hyundai" make **ACB, MCCB, and Relay** are being used by us since 2004 in our panel for various industrial and building project and **performance of the same are satisfactory**. We have not received any complaint for above equipment supplied by Spaceage "Hyundai" make.

For **Johns Electric Co. Pvt. Ltd.**



**A. P. Pal**  
**(General Manager)**

**Sameer Bhargava**  
**(Manager- Material)**

Date: 13.01.2006



dealer

# S. S. Technologies

21A, 3rd Main, 37th Cross, 8th Block, Jayanagar, BANGALORE - 560 070 Telefax : 6345797

REF:SST/BLR/101/02

DT: 26.04.04

SPACEAGE SWITCHGEARS LTD,  
GURGAON 122 001

KIND ATTN: MR.S.P.GULANI/G.M.MARKETING

Dear Sir,

This is to certify that we are using SPACEAGE-HYUNDAI MCCB'S upto 100A,3 pole 10KA,in our battery charger panels. We have used more than 1200 Numbers,and they are all working satisfactorily for the past 14 months. These panels have been supplied to KARANATAKA POWER TRANSMISSION CORPORATION LIMITED. No complaint was received as on date.

Thanking you,

Yours Faithfully,  
For S.S.TECHNOLOGIES,

AUTHORISED SIGNATORY.